



**NOTES:**

1. UNLESS OTHERWISE APPROVED BY THE CITY ENGINEER, CLEANOUTS ARE TO BE USED ONLY AS A TEMPORARY TERMINUS.
2. CLEANOUT SIZE AND MATERIAL SHALL BE SAME AS SEWER MAIN PIPE.
3. ALL CONCRETE TO BE MINIMUM 4000 PSI COMPRESSIVE STRENGTH.
4. LOCKING CLEAN OUT FRAME & COVER SHALL BE OLYMPIC FOUNDRY PART NO. M1035 D/T OR APPROVED EQUAL.



Public Works Standard Drawings

**SANITARY SEWER  
CLEAN-OUT ON MAIN LINE**

SCALE NTS

DATE JAN '23 REV.

ENGR. DW DRAWN KAE

DRAWING NO. 309