



**NOTE:**

1. ALL PRECAST SECTIONS SHALL CONFORM TO REQUIREMENTS OUTLINED IN DRAWING 301.
2. ALL CONNECTING PIPE SHALL HAVE A FLEXIBLE JOINT WITHIN 18" OF MANHOLE WALL. FOR NEW MANHOLES, USE KOR-N-SEAL BOOTS (OR EQUAL). CONNECTIONS TO EXISTING MANHOLES SHALL USE SANDED PVC COLLAR WITH GASKETED JOINT. FLEXIBLE JOINT SHALL BE NO GREATER THAN 18" FROM EXTERIOR MANHOLE WALL. SEE DRAWING 301.
3. CONSTRUCT OUTSIDE DROP PER THE DETAIL FOR 'OUTSIDE DROP CONNECTION FOR MANHOLES. SEE DRAWING 303.



Public Works Standard Drawings

**POLLUTION CONTROL MANHOLE  
WITH OUTSIDE DROP**

SCALE	NTS
DATE JAN '23	REV.
ENGR. DW	DRAWN KAE
DRAWING NO. 613-2	