



NOTES:

1. BLOWOFF NOT TO BE LOCATED IN GUTTER OR DITCH.
2. 2" FITTINGS AND PIPE SHALL BE BRASS.
3. RESILIENT SEAT GATE VALVE SAME SIZE AS WATER MAIN.
4. STRADDLE BLOCK REQUIRED AT ALL BLOWOFF LOCATIONS. SEE DRAWING 408 & 412.
5. ALL D.I. FITTINGS SHALL BE RESTRAINED WITH MEGA-LUG FOLLOWER, OR APPROVED EQUAL.

* WATER MAINS 12" DIAMETER AND LARGER REQUIRE A BUTTERFLY VALVE.



Public Works Standard Drawings

**STANDARD BLOWOFF
DETAIL**

SCALE	NTS
DATE	JAN '23
ENGR.	DW
DRAWN	KAE
DRAWING NO.	405