



**NOTES:**

1. CONCRETE SHALL BE AIR-ENTRAINED MINIMUM 4.5% AND HAVE A MINIMUM COMPRESSIVE STRENGTH OF 4000 PSI AFTER 28 DAYS.
2. ALL CONCRETE SURFACES SHALL BE SMOOTH AND FREE FROM DEFECTS AND SHALL HAVE A LIGHT BROOM TEXTURED FINISH.
3. EXPANSION JOINTS (CURB AND SIDEWALK ONLY):
  - A. TO BE PROVIDED:
    - 1) AT EACH COLD JOINT.
    - 2) AT EACH END OF DRIVEWAYS.
    - 3) AT EACH POINT OF TANGENCY OF THE CURB.
    - 4) AT LOCATIONS NECESSARY TO LIMIT SPACING TO 45 FEET.
  - B. MATERIAL TO BE USED IS "REFLEX RUBBER JOINT EXPANSION" JOINT MATERIAL, OR CITY APPROVED EQUAL, WITH A THICKNESS OF 1/2 INCH.
4. CONTRACTION JOINTS (CURB AND SIDEWALK ONLY):
  - A. SPACING TO BE NOT MORE THAN 10 FEET REGARDLESS OF LOCATION OF DRAINAGE NOTCH
  - B. THE DEPTH OF THE JOINT SHALL BE AT LEAST 1-1/2 INCHES WITH 1/2-INCH MAXIMUM RADIUS TROWEL JOINT.
  - C. PLACE JOINT ON EACH SIDE OF SCUPPER INLET (SEE DRAWING 623)
5. BASE ROCK TO BE 3/4"-0", 95% COMPACTION PER AASHTO T 180. BASE ROCK SHALL BE 6" MINIMUM IN DEPTH.
6. SIDEWALK CONTRACTION JOINTS SHALL BE PLACED IN LINE WITH ONE OF THE DRAINAGE NOTCH CORNERS.
7. SIDEWALK ELEVATION MUST BE SET ABOVE STREET INLET/OULET ELEVATIONS TO ALLOW OVERFLOW TO DRAIN TO STREET OR PIPED OVERFLOW SYSTEM AS APPLICABLE.
8. CHECK DAMS:
  - REINFORCED CONCRETE CHECK DAMS SHALL BE PLACED EVERY 30 FEET STARTING FROM UPPER END WALL
  - CHECK DAMS SPACING MAY BE DECREASED TO KEEP LONGITUDINAL SLOPE OF PLANTER FROM EXCEEDING .05%
9. THICKENED CURB AND GUTTER SHALL BE POURED MONOLITHICALLY.

Public Works Standard Drawings

ROADSIDE STORMWATER PLANTER WALL  
DETAIL

SCALE NTS

DATE MAY '24 REV. 1

ENGR. DW DRAWN KAE

DRAWING NO. 622

