



NOTES:

1. ALL PIPE AND FITTINGS SHALL MATCH METER SIZE UNLESS OTHERWISE SPECIFIED. ALL PIPE AND FITTINGS SHALL BE RESTRAINED JOINT.
2. SEE DRAWING 419-3 DETAIL NOTES AND DRAWING 419-2 PROFILE VIEW FOR ADDITIONAL REQUIREMENTS.
3. CONTRACTOR TO PROVIDE HANDWHEEL LOCK. MASTER LOCK GATE VALVE LOCKOUT OR APPROVED EQUAL.
4. INSTALL 2" CORP STOP FOR SAMPLING. SEE DRAWING 404 FOR MATERIALS.
5. SPOOL TO BE 2x PIPE DIAMETER IN LENGTH, PLACE BETWEEN GATE VALVE & METER.



Public Works Standard Drawings

4" & LARGER WATER METER VAULT (PLAN)

SCALE	NTS
DATE JUL '23	REV. 1
ENGR. DW	DRAWN KAE
DRAWING NO. 419-1	